

**From:** Peter Ditto  
**Sent:** Monday, December 05, 2016 1:07 PM  
**To:** Maria Morelli  
**Subject:** 40 Center Street Project

Maria – I have received the revised stormwater calculations and narrative for the project at 40 Center Street. The documents responded to the Town's request for updated calculations. After reviewing, it has been determined that the Town's concerns have been addressed.

With respect to DPW conditions, I request that the following condition be included in the decision:

Prior to approval of the site plan, the applicant's engineer will undertake field investigations to verify assumptions used in the design of the infiltration system. The assumptions being soil permeability, soil texture, and depth to seasonal high ground water.

Peter

The substance of this message, including any attachments, may be confidential, legally privileged and/or exempt from disclosure pursuant to Massachusetts law. It is intended solely for the addressee. If you received this in error, please contact the sender and delete the material from any computer.