



**TOWN OF BROOKLINE**  
*Massachusetts*  
**DEPARTMENT OF PUBLIC WORKS**  
Engineering & Transportation Division

*Andrew M. Pappastergion*  
Commissioner  
*Peter M. Ditto, PE*  
Director

---

## Interoffice Memorandum

To: Maria Morelli, Planning and Community Development

From: Peter M. Ditto, Director of Engineering/Transportation

Date: July 20, 2017

Re: 134 Babcock Street - 40B

cc:

Maria – I met with the Engineer who prepared the preliminary site plan/stormwater report for this project. We reviewed the project in depth and went over some concerns.

- Confirmation that there is no increased stormwater runoff to abutter's
- Calculations showing the existing and proposed runoff for 2, 10, 25, and 100 year storms
- Feasibility of installing infiltration system in garage area

I am comfortable with the information submitted to date as well as the responses to my concerns.