

## **Putterham Library Solar Project**



- **The 8000 watt solar panel system at the Putterham Library has produced 7,427 kWh of electricity over the last year. This has led to the savings of approximately 1,115 dollars (based off \$0.15 dollars per kWh) over this past year.**
- **Over the last year the 7,427 kWh produced prevents an estimated 8,900 pounds of Carbon Dioxide gas from entering the atmosphere. For reference, 8,900 pounds of CO<sub>2</sub> is the equivalent of 591 gallons of gasoline being consumed.**
- **At the average of 619 kWh produced per month, there is potential for a possible savings of about 93 dollars monthly on electricity at the Putterham Library.**



**REPORT FOR**  
 PUTTERHAM PUBLIC LIBRARY  
 959 WEST ROXBURY PARKWAY  
 CHESTNUT HILL, MA

**SYSTEM SIZE** 8000 W  
**PRODUCTION PERIOD** Feb 1 to Feb 28, 2019  
**SITE ID** 610

**OFFICE**  
 360 Merrimack Street  
 Building 9, 2nd Floor  
 Lawrence, MA 01843

**CUSTOMER SERVICE**  
 978-683-9700

**EMAIL INQUIRIES TO**  
[support@solrenview.com](mailto:support@solrenview.com)

**CONTACT SALES**  
[sales@solrenview.com](mailto:sales@solrenview.com)

**REPORT UPDATED**  
 Mar 01, 2019

**SERVICE END DATE**  
 Nov 03, 2020

PRODUCTION PERIOD	NO. OF DAYS	NEXT SCHEDULED UPDATE
Feb 1 to Feb 28	28	Apr 01, 2019

**STATEMENT SUMMARY**

Updated Reading	Feb 28, 2019	775304.0 kWh
Previous Reading	Jan 31, 2019	- 775091.2 kWh
<b>AC Energy Produced</b>	28 days	212.8 kWh
Dollar Per kWh	X	\$ 0.15
<b>Revenue</b>		<b>\$31.92</b>

**PRODUCTION HISTORY**

Month	kWh
Feb 2018	377
Mar 2018	349
Apr 2018	814
May 2018	1041
Jun 2018	1007
Jul 2018	1188
Aug 2018	941

Month	kWh
Sep 2018	642
Oct 2018	497
Nov 2018	274
Dec 2018	208
Jan 2019	89
Feb 2019	213

