



April 14, 2021

John Harding V, AIA, LEED AP
Senior Associate Principal
CUBE3
370 Merrimack Street, Suite 337
Lawrence, MA 01843

Dear Mr. Harding,

CityLift Parking Puzzle solutions require a drive aisle for access to the parking system.

The minimum recommended drive aisle dimension is 20', this allows for safe and comfortable navigation of the parking environment.

Your project at 500 Harvard appears to be more than that minimum and we do not require any additional modifications to the drive aisle.

Please let us know if you require additional clarification.

Sincerely,

Sean Fitch
Director of Sales
CityLift Parking